



DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

Certificate Number: 17967

CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO SECTION 21C OF THE ELECTRICITY SAFETY ACT 1945

ISSUED TO:

Yung Li Co Ltd

CLASS OF ARTICLE:

Plug

DESCRIPTION OF ARTICLE:

Plug (Insulated Pin)

[Non-rewirable, three-pin, flat-pin (two-insulated live pins), black thermoplastic moulded plug with a white thermoplastic insert, integrally moulded to any <HAR> certified H05VV-F 3G0.75mm², or Australian approved three-core, 0.75mm², PVC insulated and sheathed, ordinary duty circular flexible cord] 250V, 10A

EXAMINED FOR COMPLIANCE WITH: AS/NZS 3112 : 2000

TYPE REFERENCE CODE: Type No. YP-35

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number N17967 or N14876

DATE OF APPROVAL: 25 September 2001

This approval expires 25 September 2006 unless suspended, cancelled, renewed or extended.

for DIRECTOR-GENERAL



DEPARTMENT OF **FAIR TRADING**
NSW Consumer Protection Agency

ADDENDUM TO CERTIFICATE OF APPROVAL No 17967

Particulars of Modification(s)

1. Original Type No. YP-35 alternatively moulded to any of the following <HAR> certified or equivalent Australian approved flexible cords:-
 - (a) H05VV-F 3G1.00mm².
 - (b) H05VV-F 2X0.75mm².
 - (c) H05VV-F 2X1.00mm².
 - (d) H03VV-F 3G0.75mm².
 - (e) H03VV-F 2X0.75mm².
 - (f) H05VVH2-F 2X1.00mm²
 - (g) H05VVH2-F 2X0.75mm²

2. Type YP-36 being similar to original Type No. YP-35 except two-pin in lieu of three-pin, and alternatively moulded to any of the following <HAR> certified or Australian approved flexible cords:-
 - (a) H03VVH2-F 2X0.75mm².
 - (b) H05VVH2-F 2X0.75mm².
 - (c) H05VVH2-F 2X1.00mm².
 - (d) H03VV-F 2X0.75mm².
 - (e) H05VV-F 2X0.75mm².
 - (f) H05VV-F 2X1.00mm².

Approved: 25 September 2001

for DIRECTOR-GENERAL

OFFICE OF FAIR TRADING

NSW Consumer Protection Agency
Department of Commerce

ADDENDUM TO CERTIFICATE OF APPROVAL No 17967

Particulars of Modification(s)

Model No. YP-36 to use the alternative approval mark N15572.

Approved: 03 March 2005

A handwritten signature in black ink, appearing to be 'R. K.', with a long horizontal line extending to the right.

for Commissioner

Ref: 17967/3

ADDENDUM TO CERTIFICATE OF APPROVAL 17967

Particulars of Modification(s)

- (a) Original Type No. YP-35 alternatively moulded to a 'Yung Li' Type H05VV-F 3G1.5mm² flexible cord (Q04083).
- (b) General Modification:
Plugs now comply with AS/NZS3112 : 2004.

Approved: 01 May 2006



for Commissioner for Fair Trading

ADDENDUM TO CERTIFICATE OF APPROVAL 17967

Particulars of Modification(s)

1. Type YP-35 alternatively moulded to any <HAR> certified H05RR-F 3G1.00mm² or equivalent Australian approved flexible cord.
2. Type YP-39 being similar to Type YP-35 except :-
 - (a) Having 15A in lieu of 10A construction.
 - (b) Marked 15A in lieu of 10A.
 - (c) Alternatively moulded to any <HAR> certified H05VV-F 3G1.5mm² or H05RR-F 3G1.5mm² or equivalent Australian approved flexible cords.
3. General Modification.
Plugs now comply with AS/NZS3112:2001 A1

Approved: 10 May 2007



for Commissioner for Fair Trading



Fair
Trading

Ref: NSW17967/8

FILE COPY

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW17967 Particulars of Modification(s)

Model No. YP-35 is alternatively moulded to any <HAR> certified H05RN-F 3G0.75/1.0mm² or equivalent Australian approved flexible cord. Plug enclosure and pin supporter can be of any colour;

Model No. YP-35L is identical to YP-35 except for cord connection of side-entry type in lieu of straight-entry. It can be moulded to any <HAR> certified H05RN-F 3G0.75/1.0mm², or H05RR-F 3G0.75/1.0/1.5mm², or H05VV-F 3G0.75/1.0/1.5mm², or equivalent Australian approved flexible cord. Plug enclosure and pin supporter can be of any colour;

Model No. YP-36 is alternatively moulded to any <HAR> certified H05RN-F 2x0.75/1.0mm² or equivalent Australian approved flexible cord. Plug enclosure and pin supporter can be of any colour;

Model No. YP-39 is alternatively moulded to any <HAR> certified H05RN-F 3G0.75/1.0mm², or H05VV-F 3G2.5mm², or equivalent Australian approved flexible cord. Plug enclosure and pin supporter can be of any colour.

This certificate will expire on 25/09/2016

Approved: 17 July 2013



18/7/2013

For Commissioner for Fair Trading



Fair
Trading

Ref: NSW17967/9

RENEWAL OF CERTIFICATE OF APPROVAL: NSW17967

Particulars of Renewal

The approval of Plug Type No. YP-35 and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 14/04/2021 unless it is renewed, extended, suspended or cancelled.


For Commissioner for Fair Trading

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW17967

Change of Particulars

Change of Name			
Title:			
New Name:			
ABN:			
ACN:			
Postal Address:			
Suburb:		State:	
Postcode:		Country:	
Model Changes			
Title:			
Model Reference Code:			
Trade Name or Mark:			
Other Description:	Regulatory Compliance Mark (RCM) is not an appropriate exclusive mark to replace approval mark assigned in this certificate. However, RCM is not prohibited to be marked on the approved articles covered in this certificate, provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the articles are fulfilled.		
Manufacturers Name:			
Postal Address:			
Suburb:		State:	
Postcode:		Country:	

This certificate will expire on 14/04/2021

Approved pursuant to Clause 16 (3) (b) of the Gas and Electricity (Consumer Safety) Regulation 2018:

 4 February 2021

For Secretary, Department of Customer Service



**Fair
Trading**

Ref: NSW17967/12

RENEWAL OF CERTIFICATE OF APPROVAL: NSW17967

Particulars of Renewal

The approval of Plug Type No. YP-35 and all approved modifications has been renewed for a period of FIVE years.

The Approval expires on 14/04/2026 unless it is renewed, extended, suspended or cancelled.

Approved pursuant to Clause 11 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018

4 February 2021

For Secretary, Department of Customer Service


ZEICHENGENEHMIGUNG MARKS APPROVAL

Yung-Li Co. Ltd.
Da Pu Industrial Zone, Cang Zi
Chang Ping Town
523571 DONG GUAN CITY
Guangdong
CHINA

ist berechtigt, für ihr Produkt /
is authorized to use for their product

Gerätesteckdose, nicht-wiederanschließbar
Connector, non-rewirable

die hier abgebildeten markenrechtlich geschützten Zeichen
für die ab Blatt 2 aufgeführten Typen zu benutzen /
the legally protected Marks as shown below for the types referred to on page 2 ff.



Geprüft und zertifiziert nach /
Tested and certified according to

DIN EN 60320-1 (VDE 0625-1):2016-04; EN 60320-1:2015+AC:2016
DIN EN 60320-3 (VDE 0625-3):2015-11; EN 60320-3:2014
IEC 60320-1:2015
IEC 60320-3:2014

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification

G. Heine

VDE Zertifikate sind nur gültig bei Veröffentlichung unter:
VDE certificates are valid only when published on:

VDE

Aktenzeichen: 1609800-1550-0003 / 232784

File ref.:

Ausweis-Nr. 40029577

Certificate No.

Weitere Bedingungen siehe Rückseite und Folgeblätter /
further conditions see overleaf and following pages

Offenbach, 2010-03-05

(letzte Änderung/updated 2017-12-13)

Blatt 1
Page

<http://www.vde.com/zertifikat>
<http://www.vde.com/certificate>



Name und Sitz des Genehmigungs-Inhabers / *Name and registered seat of the Certificate holder*

Yung-Li Co. Ltd., Da Pu Industrial Zone, Cang Zi, Chang Ping Town, 523571 DONG GUAN CITY, Guangdong, CHINA

Aktenzeichen / *File ref.*

1609800-1550-0003 / 232784 / TL3 / E

letzte Änderung / *updated*

2017-12-13

Datum / *Date*

2010-03-05

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40029577.

This supplement is only valid in conjunction with page 1 of the Certificate No. 40029577.

Gerätesteckdose, nicht-wiederanschließbar *Connector, non-rewirable*

Typ(en) / *Type(s)*

- 1) YC-12
- 2) YC-12L

Bemessungsspannung
Rated voltage

AC 250 V

Bemessungsstrom
Rated current

10 A

Polzahl
Number of poles

2-polig mit Schutzkontakt
2-pole with earthing contact

Bauart
Kind of construction

Normblatt C13
standard sheet C13

Ausführung(en)
Construction(s)

zentrale Leitungseinführung
straight cable entry
Für / *for* 1)

abgewinkelte Leitungseinführung
angled cable entry
Für / *for* 2)

Warenzeicheninhaber
Trademark holder

Yung Li Co. Ltd.

Produktinformation

siehe Anlage Nr. 300 + 700 + 702 + 703 + 900 vom 2017-11-02
und
Anlage Nr. 701 vom 2017-12-13

Product information

*see Appendix No. 300 + 700 + 702 + 703 + 900 dated
2017-11-02
and
Appendix No. 701 dated 2017-12-13*

Fortsetzung siehe Blatt 3 /
continued on page 3

Certificate Number: 22012

CERTIFICATE OF APPROVAL

ISSUED PURSUANT TO THE ELECTRICITY (CONSUMER SAFETY) ACT 2004

ISSUED TO:

Yung Li Co Ltd

CLASS OF ARTICLE:

Appliance Connector

DESCRIPTION OF ARTICLE:

Appliance Connector

(Non-rewirable, straight entry, Group 1, C13 appliance connector for cold conditions for Class I equipment integrally moulded to any <HAR> certified H05VV-F 3G1.00mm² or Australian approved three-core, 1.00mm², PVC insulated and sheathed ordinary duty circular flexible cord)
250V, ac, 10A

EXAMINED FOR COMPLIANCE WITH: AS/NZS 60320.1 : 2004

TYPE REFERENCE CODE: Type No. YC-12

APPROVAL MARK:

Each electrical article of the abovementioned type shall be marked with Approval Number NSW22012 or N14877 ;or
the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

DATE OF APPROVAL: 31 October 2006

This approval expires 31 October 2011 unless suspended, cancelled, renewed or extended.



for Commissioner for Fair Trading

ADDENDUM TO CERTIFICATE OF APPROVAL 22012

Particulars of Modification(s)

1. Type No. YC-12 alternatively moulded to any <HAR> certified H05VV-F 3G0.75mm² or Australian approved, three-core, 0.75mm², PVC insulated and sheathed ordinary duty circular flexible cord not exceeding two metres in length.
2. Type No. YP-32 being similar to original Type No. YC-12 except a Standard Sheet 'E' Interconnection Plug Connector (AS/NZS 60320.2.2) alternatively moulded to either:-
 - (a) Any <HAR> certified H05VV-F 3G1.00mm² or equivalent Australian approved flexible cord; or
 - (b) Any <HAR> certified H05VV-F 3G0.75mm² or equivalent Australian approved flexible cord not exceeding two metres in length.
3. Type No. YC-12 alternatively moulded to any <HAR> certified H05VV-F 3G1.5mm² or Australian approved three-core, 1.5mm², PVC insulated and sheathed ordinary duty circular flexible cord.

Approved: 31 October 2006



for Commissioner for Fair Trading



Fair
Trading

Ref: NSW22012/2

RENEWAL OF CERTIFICATE OF APPROVAL NSW22012

PARTICULARS OF RENEWAL

The approval of the original appliance connector Model YC-12 and approved modifications has been renewed.

The Approval expires on 31/10/2016 unless it is renewed, extended, suspended or cancelled

A handwritten signature in black ink, appearing to be "D. Smith".

For Commissioner for Fair Trading



**Fair
Trading**

Ref: NSW22012/3

RENEWAL OF CERTIFICATE OF APPROVAL: NSW22012

Particulars of Renewal

The approval of the original appliance connector Model YC-12 and approved modifications has been renewed for FIVE years.

The Approval expires on 31/10/2021 unless it is renewed, extended, suspended or cancelled.

For Commissioner for Fair Trading


ZEICHENGENEHMIGUNG MARKS APPROVAL

Yung-Li Co. Ltd.
Da Pu Industrial Zone, Cang Zi
Chang Ping Town
523571 DONG GUAN CITY
Guangdong
CHINA


ist berechtigt, für ihr Produkt /
is authorized to use for their product

Starkstromleitungen für allgemeine Anwendungen
- Flexible Leitungen
mit thermoplastischer PVC-Isolierung
Cables for general applications
- Flexible cables with
thermoplastic PVC insulation


die hier abgebildeten markenrechtlich geschützten Zeichen
für die ab Blatt 2 aufgeführten Typen zu benutzen /
the legally protected Marks as shown below for the types referred to on page 2 ff.



oder/or



oder/or



schwarz
black

rot
red

Geprüft und zertifiziert nach /
Tested and certified according to

DIN EN 50525-2-11 (VDE 0285-525-2-11):2012-01; EN 50525-2-11:2011

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / *Certification*

K. Prohaska
K. Prohaska

VDE Zertifikate sind nur gültig bei Veröffentlichung unter:
VDE certificates are valid only when published on:

Aktenzeichen: 1609800-5140-0005 / 171941
File ref.:

Ausweis-Nr. 40010145
Certificate No.

Blatt 1
Page

Weitere Bedingungen siehe Rückseite und Folgeblätter /
further conditions see overleaf and following pages

Offenbach, 2004-04-27
(letzte Änderung/updated 2012-09-25)

<http://www.vde.com/zertifikat>

<http://www.vde.com/certificate>

Name und Sitz des Genehmigungs-Inhabers / *Name and registered seat of the Certificate holder*

Yung-Li Co. Ltd., Da Pu Industrial Zone, Cang Zi, Chang Ping Town, 523571 DONG GUAN CITY,
Guangdong, CHINA

Aktenzeichen / *File ref.*

1609800-5140-0005 / 171941 / FG42 / HEG

letzte Änderung / *updated* Datum / *Date*

2012-09-25

2004-04-27

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40010145

This supplement is only valid in conjunction with page 1 of the Certificate No. 40010145.

Starkstromleitungen für allgemeine Anwendungen

- Flexible Leitungen

mit thermoplastischer PVC-Isolierung

Cables for general applications

- Flexible cables with

thermoplastic PVC insulation

Typ(en) / *Type(s)*:

H03VV-F 2...4 x 0,5...0,75 mm²

+

H03VVH2-F 2 x 0,5...0,75 mm²

+

H05VV-F 2...5 x 0,75...4 mm²

+

H05VVH2-F 2 x 0,75...1,0 mm²

+

Leitungsbauart

Standardleitungen

Type of cable

General purpose cables

Firmenzeichen

YUNG LI

Trademark

Dieser Zeichengenehmigungs-Ausweis bildet eine Grundlage für die EG-Konformitätserklärung und CE-Kennzeichnung durch den Hersteller oder dessen Bevollmächtigten und bescheinigt die Konformität mit den grundlegenden Schutzanforderungen der **EG-Niederspannungsrichtlinie 2006/95/EG** mit ihren Änderungen.

This Marks Approval is a basis for the EC Declaration of Conformity and the CE Marking by the manufacturer or his agent and proves the conformity with the essential safety requirements of the EC Low-Voltage Directive 2006/95/EC including amendments.

VDE Prüf- und Zertifizierungsinstitut GmbH

VDE Testing and Certification Institute

Fachgebiet FG42

Section FG42

VDE Prüf- und Zertifizierungsinstitut Zeichengenehmigung

Ausweis-Nr. / Beiblatt /
Certificate No. Supplement
40010145

Name und Sitz des Genehmigungs-Inhabers / *Name and registered seat of the Certificate holder*

Yung-Li Co. Ltd., Da Pu Industrial Zone, Cang Zi, Chang Ping Town, 523571 DONG GUAN CITY,
Guangdong, CHINA

Aktenzeichen / *File ref.*

1609800-5140-0005 / 171941 / FG42 / HEG

letzte Änderung / *updated* Datum / *Date*

2012-09-25

2004-04-27

Dieses Beiblatt ist Bestandteil des Zeichengenehmigungsausweises Nr. 40010145.

This supplement is part of the Certificate No. 40010145.

Starkstromleitungen für allgemeine Anwendungen

- Flexible Leitungen

mit thermoplastischer PVC-Isolierung

Cables for general applications

- Flexible cables with

thermoplastic PVC insulation

Fertigungsstätte(n)

Place(s) of manufacture

Referenz/*Reference*

30008928

Yung-Li Co. Ltd.

Da Pu Industrial Zone, Cang Zi

Chang Ping Town

523571 DONG GUAN CITY

Guangdong

CHINA

VDE Prüf- und Zertifizierungsinstitut GmbH

VDE Testing and Certification Institute

Fachgebiet FG42

Section FG42

Name und Sitz des Genehmigungs-Inhabers / *Name and registered seat of the Certificate holder*

Yung-Li Co. Ltd., Da Pu Industrial Zone, Cang Zi, Chang Ping Town, 523571 DONG GUAN CITY,
Guangdong, CHINA

Aktenzeichen / *File ref.*

1609800-5140-0005 / 171941 / FG42 / HEG

letzte Änderung / *updated* Datum / *Date*

2012-09-25

2004-04-27

Dieses Blatt gilt nur in Verbindung mit Blatt 1 des Zeichengenehmigungsausweises Nr. 40010145

This supplement is only valid in conjunction with page 1 of the Certificate No. 40010145.

Genehmigung zum Benutzen des auf Seite 1 abgebildeten markenrechtlich geschützten Zeichens des VDE:

Grundlage für die Benutzung sind die Allgemeinen Geschäftsbedingungen (AGB) der VDE Prüf- und Zertifizierungsinstitut GmbH (www.vde.com\AGB-Institut). Das Recht zur Benutzung erstreckt sich nur auf die bezeichnete Firma mit den genannten Fertigungsstätten und die oben aufgeführten Produkte mit den zugeordneten Bezeichnungen. Die Fertigungsstätte muss so eingerichtet sein, dass eine gleichmäßige Herstellung der geprüften und zertifizierten Ausführung gewährleistet ist.

Die Genehmigung ist so lange gültig wie die VDE-Bestimmungen gelten, die der Zertifizierung zugrunde gelegen haben, sofern sie nicht auf Grund anderer Bedingungen aus der VDE Prüf- und Zertifizierungsordnung (PM102) zurückgezogen werden muss.

Der Gültigkeitszeitraum einer VDE-GS-Zeichengenehmigung kann auf Antrag verlängert werden. Bei gesetzlichen und / oder normativen Änderungen kann die VDE-GS-Zeichengenehmigung ihre Gültigkeit zu einem früheren als dem angegebenen Datum verlieren.

Produkte, die das Biozid Dimethylfumarat (DMF) enthalten, dürfen gemäß der Kommissionsentscheidung 2009/251/EG nicht mehr in den Verkehr gebracht oder auf dem Markt bereitgestellt werden.

Der VDE-Zeichengenehmigungsausweis wird ausschließlich auf der ersten Seite unterzeichnet.

Approval to use the legally protected Mark of the VDE as shown on the first page:

Basis for the use are the general terms and conditions of the VDE Testing and Certification Institute (www.vde.com\terms-institute). The right to use the mark is granted only to the mentioned company with the named places of manufacture and the listed products with the related type references. The place of manufacture shall be equipped in a way that a constant manufacturing of the certified construction is assured.

The approval is valid as long as the VDE specifications are in force, on which the certification is based on, unless it is withdrawn according to the VDE Testing and Certification Procedure (PM102E).

The validity period of a VDE-GS-Mark Approval may be prolonged on request. In case of changes in legal and / or normative requirements, the validity period of a VDE-GS-Mark Approval may be shortened.

Products containing the biocide dimethylfumarate (DMF) may not be marketed or made available on the EC market according to the Commission Decision 2009/251/EC.

The approval is solely signed on the first page.



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA-190646-EA

Certificate Holder: Yung Li Co., Ltd.
Dapu Industrial Zone, Gangzi,
Changping Town, Dongguan,
Guangdong
P.R. China

Class Description: Supply Flexible Cord
Product Description: Polyvinyl chloride sheathed cord
Brand Name: Yung LI
Model No.: H05VV-F 2x2.5mm²
Markings: 300/500V
Ordinary, Circular
Standard: AS/NZS 60227.5:2003 Inc A1
Conditions: Nil

Approval Mark: SAA-190646-EA or RCM

Date First Registered: 22 March 2019
Date of Expiry: 22 March 2024

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-19 190646/1



A P P R O V A L S ®

Certificate of Approval

Addendum

Certificate No.: SAA-190646-EA

Date of Issue: 22 March 2019

Class Description: Supply Flexible Cord
Product Description: Polyvinyl chloride sheathed cord

Additional Models	Description
H03VVH2-F 2x0.5mm ²	300/300V, Light, Flat
H03VVH2-F 2x0.75mm ²	300/300V, Light, Flat
H03VV-F 2x0.5mm ²	300/300V, Light, Circular
H03VV-F 2x0.75mm ²	300/300V, Light, Circular
H03VV-F 3x0.5mm ²	300/300V, Light, Circular
H03VV-F 3x0.75mm ²	300/300V, Light, Circular
H05VVH2-F 2x0.75mm ²	300/500V, Ordinary, Flat
H05VVH2-F 2x1.0mm ²	300/500V, Ordinary, Flat
H05VV-F 2x0.75mm ²	300/500V, Ordinary, Circular
H05VV-F 2x1.0mm ²	300/500V, Ordinary, Circular
H05VV-F 2x1.5mm ²	300/500V, Ordinary, Circular
H05VV-F 3x0.75mm ²	300/500V, Ordinary, Circular
H05VV-F 3x1.0mm ²	300/500V, Ordinary, Circular
H05VV-F 3x1.5mm ²	300/500V, Ordinary, Circular
H05VV-F 3x2.5mm ²	300/500V, Ordinary, Circular

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 22-03-19 190646/2